



## **ADDENDUM #1**

April 24, 2009

**RE: Toledo Executive Airport – Construct T-Hangar**

**FROM:** Tina Perkins, Construction Administrator  
Toledo – Lucas County Port Authority  
One Maritime Plaza  
Toledo, Ohio 43604-1866  
Website: toledoport.org  
P: (419)243-8251

**TO:** Plan Holders

This Addendum forms a part of the Contract Documents and modifies the original Procurement Documents, as noted below. **Acknowledge receipt of this Addendum in the space provided on the Form Proposal.** Failure to do so may subject Bidder to disqualification.

### **BID DOCUMENT CLARIFICATION**

1. Revised drawings – SEE ATTACHED
  - Drawings Title sheet
  - Site Plan (SP-1)
  - Plan and Details (A-1)
2. General Conditions – SEE ATTACHED
  - Article 5 – Bonds and Insurance
    - 5.3.1 c). Commercial and General Liability Revised
3. Pre-Bid Meeting Sign-in sheet – SEE ATTACHED

### **ANSWERS TO PREBID QUESTIONS:**

1. Will radiant tube heaters will be used to heat the facility?  
Answer: Radiant tube heaters are not a part of this project.
2. Foundation modifications are to be made by others, is there a separate bidding package for that scope?  
Answer: There is no separate bidding package for foundation modifications.

### **END OF ADDENDUM #1**