



Clarification No. 1

June 7, 2021

RE: Dana Toledo Axle Plant Parking Lot Expansion

FROM: Tina Perkins, Project Administrator
Toledo – Lucas County Port Authority
One Maritime Plaza, 7th floor
Toledo, Ohio 43604-1866
Website: toledoportauthority.org
P. (419)243-8251

TO: Plan Holders

This clarification to the addendum supplements and amends the original drawings and specifications. It shall be taken into account in preparing proposals and shall become a part of the Contract Documents. **Acknowledge receipt of this Clarification in the space provided on the Form of Proposal.** Failure to do so may subject Bidder to disqualification.

I. Electrical

A. Drawings

1. E2.0 – Electrical Site Plan (Drawing not re-issued)
 - a) Revised note 5 to change tier rating of handhole. Note 5 shall read:
LIGHTING HANDHOLE; 10" X 15" X 18" DEEP POLYMER CONCRETE TIER 22 OPEN BOTTOM CONDUIT JUNCTION BOX WITH ONE-PIECE TIER 22 HEAVY DUTY BOLTED COVER, SUITABLE FOR NON-DELIBERATE TRAFFIC. LEGEND ENGRAVED "LIGHTING"; QUAZITE #PT1015 OR EQUAL. HANDHOLE BOX SHALL BE INSTALLED ALONGSIDE AND CLOSE FROM POLE BASE (TO MEET MANUFACTURER'S RECOMMENDATIONS) FOR UNDERGROUND LIGHTING BRANCH CIRCUIT CONNECTION TO BASE MOUNTED SITE LIGHTING POLE AND LUMINARIES WITH PROVISIONS FOR EXTENSIONS TO ADDITIONAL POLES.

End of Clarification No. 1